

Green Capacity Planning: Theory and Practice

Amy Spellmann, Optimal Innovations

Richard Gimarc, HyPerformix

Charles Gimarc, LSI

St. Louis CMG

May 18, 2010

Agenda

- Green Capacity Planning
 - Methodology
 - Energy Footprint Projection

- Case Study
 - Server Upgrade Scenario
 - Virtualized Scenario
 - Storage Upgrade Options
 - Comparison

- Conclusion


Green Capacity Planning: What is it?

- Extends established methods & best practices
- Introduces an ***energy footprint projection***
- Views energy as a new resource for capacity planners to include in their analysis
- Focuses on cost-effective technologies & practices to manage today's challenges




Green Capacity Planning Combines Tools & Best Practices


Predictive Capacity Planning



Energy Footprint Projection



Cost & Capacity Comparison



Commercial Capacity
Planning Tools

Established
Methods

Professional
Services

New Resource to
Evaluate


Green Capacity
Planning

Green Capacity Planning: Why do we need it?


- By 2010, IDC expects that for every dollar of new server spending, an additional \$0.70 will be needed for power and cooling
- 2% of the world's carbon dioxide emissions come from IT equipment--the same amount of pollution as the airline industry creates – Wall Street Journal
- With the advent of high density computer equipment such as blade servers, many data centers have maxed out their power and cooling capacity - Gartner
- New data center construction projects cost \$250M and up
- Google spent \$600M each for four new data centers in 2007

Green Capacity Planning: Value

- Determines the most efficient way to meet business needs while minimizing computing, power, cooling, space requirements
- Assures SLAs are met
 - Response times
 - Utilization
- Evaluates potential cost & energy savings of virtualization




Green Capacity Planning: Factors



Cost Effective Solution

Methodology: Enhanced Traditional Approach



Green Capacity Planning Metrics

■ New Inputs

- Energy Footprint (calculated or measured)
- PUE
- Active Idle
- Max Power
- Cost of electricity

■ Comparison Metrics

- Energy Footprint Projection
- Rack Space
- Cumulative Costs
- Productivity (Trans per kWh)

In addition to traditional capacity planning metrics, e.g., Utilization, Response Time, etc.

Energy Footprint Projection

- Determine energy required by each system component
 - Obtain active-idle, average, maximum power from measurements or vendor specifications
 - Compute energy usage over time (e.g., monthly)
- Add "site" infrastructure energy
 - Overhead energy for running components in the data center
 - Includes: cooling, fans, power distribution units, lighting, etc.



Energy Footprint Projection: Terminology

■ Terminology

➤ Power

- Spot measurement, single point in time
- Measured in watts (W)

➤ Energy

- Power consumption over a period of time
- Measured in kilowatt hours (kWh)
- You pay for energy, not power


Power ≠ Energy

■ Energy estimation

- Component-level power requirements (W)
- Estimate consumption over a period of time (e.g., 1 day)

Power x Time = Energy Usage

Energy Footprint Projection: Data Center Energy Usage



General Flow

- Energy enters in the form of electricity
- IT equipment used to store & manipulate information
- IT equipment generates heat
- Site infrastructure removes generated heat

Questions

- What if your data center's power input is maximized?
- How can you increase your compute power without increasing your power draw?
- Can you improve site efficiency?
- Do you really need to build a new data center?

Energy Footprint Projection: Components


- Two components
 - IT Equipment
 - Site Infrastructure

- Approach
 - *Compute* IT energy
 - *Estimate* Site energy

Power Usage Effectiveness


$$PUE = \frac{\text{Site Power} + \text{IT Power}}{\text{IT Power}} \geq 1.0$$

- Today's average of 2.0
- Use to estimate Site energy
- Energy = Power X Time



$$EFP(\text{Day}) = IT_kWh_{\text{Computed}} + Site_kWh_{\text{Estimated}}$$

Energy Footprint Projection: Server-Centric Component Contribution



Component Distribution Varies Widely With Business Service

Energy Footprint Projection: Estimating EFP(Day)

$$\text{EFP(Day)} = \text{IT_kWh}_{\text{Computed}} + \text{Site_kWh}_{\text{Estimated}}$$

Given Power_i for each IT device:

$$\text{IT_kWh}_{\text{Computed}} = (\sum \text{Power}_i) \times (24 \text{ Hours/Day})$$

Power Usage Effectiveness:

$$\text{PUE} = \frac{\text{SitePower} + \text{ITPower}}{\text{ITPower}} \geq 1$$


Estimate Site_kWh using assumed PUE:

$$\text{Site_kWh}_{\text{Estimated}} = \text{IT_kWh}_{\text{Computed}} \times (\text{PUE} - 1)$$

$$\text{EFP(Day)} = \text{PUE} \times \text{IT_kWh}_{\text{Computed}}$$

Energy Footprint Projection: Server Power Usage

- How do you estimate the power usage of a server?
- Power specifications for a server (W):
 - Power supply
 - Max Power
 - Active Idle
- Approximation
 - Server power usage scales linearly with processor utilization
 - Validated across various servers $\pm 5\%$ [TGG2008]



$$\text{Power@Util\%} = (\text{MaxW} - \text{IdleW}) \times \left(\frac{\text{Util\%}}{100} \right) + \text{IdleW}$$

Energy Footprint Projection: Server Power Usage - Example




SPECpower_ssj2008

Copyright © 2008 Standard Performance Evaluation Corporation

Dell Inc. PowerEdge 2950 III (Intel Xeon E5440)			SPECpower_ssj2008 = 719 overall ssj_ops/watt		
Test Sponsor:	Dell Inc.	SPEC License #:	55	Hardware Availability:	Mar-2008
Tested By:	Dell Inc.	Test Location:	Round Rock, TX, USA	Software Availability:	Oct-2007
System Source:	Single Supplier	Test Date:	Feb 12, 2008	Publication:	Feb 27, 2008

Benchmark Results Summary

Performance			Power	Performance to Power Ratio
Target Load	Actual Load	ssj_ops	Average Power (W)	
100%	99.2%	298,188	254	1,172
90%	89.7%	269,554	249	1,084
80%	80.4%	241,701	242	997
70%	70.3%	211,354	234	901
60%	60.0%	180,508	225	801
50%	49.5%	148,959	214	695
40%	40.4%	121,477	203	599
30%	30.2%	90,702	190	477
20%	20.1%	60,493	177	342
10%	10.0%	29,990	161	187
Active Idle		0	147	0
			Σssj_ops / Σpower =	719



$$\text{Power@Util\%} = (\text{MaxW} - \text{IdleW}) \times \left(\frac{\text{Util\%}}{100} \right) + \text{IdleW}$$


$$\text{Power@70\%} = (254 - 147) \times \left(\frac{70}{100} \right) + 147$$

$$\text{Power@70\%} = 221.9$$

Assume server power usage scales linearly with CPU utilization

- Extend data center lifetime while supporting future business growth
 - Two year planning based on business projections
 - Limited data center power
- Develop a capacity plan for growth/change
 - Upgrade/add servers
 - Leverage virtualization
- Align with business requirements
 - Predict required infrastructure to meet SLAs
 - Reduce today's energy footprint
 - Select cost-effective solution

- Growing eCommerce system
- Business Requirements
 - 5% monthly growth
 - 2-year upgrade plan to support growth & meet SLAs
 - Reduce IT & site energy costs
 - Optimize hardware utilization
 - Evaluate virtualization as an energy saving solution



Baseline System

- 24 servers
- 42U Rack space


■ TPC-W Benchmark

- Published TPC-W Benchmark Result
 - May 2002
 - Full Disclosure Report - details
- Simulates Web-based browsing & shopping
- Provides the baseline specification
 - Application architecture
 - IT equipment
 - Workload
 - Utilization

Benchmark Workload

- 100,000 Items
- 76,000 Users
- 9,709 WIPs@100,000


Case Study: Baseline Architecture & IT



Function	# of Systems	System	OS	Processors	Memory
Web/Image/Cache Fill Server	18	PowerEdge 1650	Microsoft Windows Powered	2 - Pentium III 1.4GHz/512kB L2	2GB
Image/DNS Server	2	PowerEdge 1650	Windows 2000 Advanced Server	2 - Pentium III 1.4GHz/512kB L2	2GB
Web Cache	3	PowerEdge 1650	Volera Excelerator 2.2	1 - Pentium III 1.4GHz/512kB	2GB
Database Server	1	PowerEdge 6650	Windows 2000 Advanced Server	4 - Intel Xeon MP 1.6GHz/1MB L3	4GB

Case Study: Baseline Database Storage


- 12 HDD per enclosure
- Ultra320 SCSI
- 5 enclosures
- 3U rack space per enclosure
- 41 total disks






Purpose	Enclosure	# of Disk	RAID Level	Capacity (GB)
Log	1	10	1 / 0	135
Backup	2	7	5	393
Database	3, 4, 5	24	0	812

Case Study: Database Technology Upgrade

- Move to current SAS technology that will allow scaling for 2 years
- Replace original Ultra 320 SCSI storage subsystem with newer SAS (Serial Attached SCSI) technology
- Reduce power by changing from 3½" to 2½" SFF disks
- Triple storage density by moving from 12 disks in a 3U space to 24 disks in a 2U space
- Achieve higher performance to meet the demands of the system after 2 years of workload growth
- Decrease power per enclosure by 50%



Case Study: Modeling Approach



- Utilizing HyPermix's Capacity Manager for Capacity Analysis
- Dell's Datacenter Capacity Planner for Power Metrics
- Integrating results for Server/Resource Capacity, Power Requirements & Business Metrics

Case Study: Modeling Scenario Strategy

Server Upgrade

- 5% monthly growth for 2 years
- 70% capacity threshold
- Optimize the number of upgrades
- Dell PE 2950 for the database
- *Dell PE 1850 for all other servers*

Virtualization


- 5% monthly growth for 2 years
- 70% capacity threshold
- Optimize the number of upgrades
- Dell PE 2950 for the database
- *Virtualize all other servers on a pool of Dell PE 1950s*
- *Optimize use of virtual hosts*

For each scenario

1. Determine infrastructure required to support workload growth (Capacity Manager)
2. Estimate energy footprint
3. Calculate cost of IT equipment & energy


Scenario - Server Upgrade: Database Storage Provisioning

- **Growth Assumption:**
 - Database storage grows at same rate as workload (5% per month)
- **Baseline Assumptions:**
 - Use same capacity disks
 - 36GB for Log & Database
 - 73GB for Backup
 - Same disk fill factor
 - One RAID adapter per enclosure
- **Method:**
 - Estimate required disk space based on growth
 - Compute number of disks
 - Compute number of enclosures & adapters




- **Results:**
 - Start with 4 enclosures
 - Add new enclosure when disk count reaches 24

Scenario - Server Upgrade: Timeline




- Minimize number of server upgrade points
- Servers upgraded once per 3-month period
- Retire old servers (replace with faster more efficient servers)

Scenario - Server Upgrade: Infrastructure - Final Plan



- Final 2-year capacity plan
- Infrastructure supports 5% growth over 24 months
- Server upgrades grouped to reduce downtime (one upgrade per quarter)

Scenario - Server Upgrade: Infrastructure Components




At end of 2-years

- 27 Servers
- \$150K

21 kWh / mo
42U rack

Scenario - Server Upgrade: Monthly Energy Footprint



Server Upgrade

- 5% monthly growth for 2 years
- 70% capacity threshold
- Optimize the number of upgrades
- Dell PE 2950 for the database
- *Dell PE 1850 for all other servers*


Virtualization

- 5% monthly growth for 2 years
- 70% capacity threshold
- Optimize the number of upgrades
- Dell PE 2950 for the database
- *Virtualize all other servers on a pool of Dell PE 1950s*
- *Optimize use of virtual hosts*

For each scenario

1. Determine infrastructure required to support workload growth (Capacity Manager)
2. Estimate energy footprint
3. Calculate cost of IT equipment & energy

Scenario - Virtualization: Server Utilization Results



Example - Storage Upgrade: Replace HDD with SSD


- Replace Database rotating disks with SSDs
 - Random workload
 - Other stores (Log, Backup) are mostly sequential
- Keep same data throughput and latency levels
 - Maintain SLA
- Reduce
 - DataCenter footprint
 - Power
 - Cost (CAPEX, Operating)
- Compare Storage at month 24 only

Example - Storage Upgrade: Replace HDD with SSD

- Replace 4 HDD with one SSD
 - Similar capacity, will be sufficient to maintain performance
 - Reduced space, power & cost (capex)

Feature	HDD (3G SAS)	SSD (3G SATA)
Capacity	36 GB	128 GB
Size	2.5" SFF	2.5" SFF
Active Power, W	7.9	2.8
Idle Power, W	5.8	0.1
Cost, \$/disk (est)	300	400
Sequential IOPs	30K – 100K	50K – 100K
Random RD IOPs	300	4.2K – 30K *
Random Wr IOPs	150	2.6K – 25K *
Sequential RD MB/s	120	240

Example - Storage Upgrade: Replace HDD with SSD




Scenario Comparison: Server Upgrade vs. Virtualization

	Server Upgrade	Virtualization
Server Count	27	6
Energy Footprint	21,000 kWh	7,700 kWh
Cumulative Cost	\$150,000	\$120,000
Rack Space (U)	42	21

Scenario Comparison: Infrastructure Sprawl


Baseline




27 svr, 42U
21 kWh/mo
31,300 WIPSB

Server Upgrade

Virtualization




24 svr, 42U
15.6 kWh/mo
9,700 WIPSB




6 svr, 21U
7.7 kWh/mo
31,300 WIPSB

Scenario - Virtualization: Monthly Energy Footprint

Server Upgrade: Energy Footprint per Month




Virtualization: Energy Footprint per Month





Significant reduction:
Energy Footprint (50%)

Scenario Comparison: Rack Space



Scenario Comparison: Detailed Cumulative Cost



- HW-Storage Cost (\$)
- Cumulative Energy-IT Cost (\$)
- HW-Server Cost (\$)
- Cumulative Energy-Site Cost (\$)

- Identical storage costs
- Virtualization server cost 30% lower
- Energy cost 60% less


- Emerging technologies are already impacting Green Capacity Planning in the DataCenter
 - SSD
 - Reduce # of disks & power
 - Multicore Processors
 - Higher CPU capacity in same physical & power footprint
 - Dynamic Power Management
 - Manage power of subsystems & components relative to current load
 - Virtualization
 - Combine multiple servers into one server
- Facilities improvements
 - Creative Cooling
 - Fluid cooling, higher temp operation
 - Decreasing PUE
 - Driving PUE very close to 1.0 (lights, fans, chiller)
 - Climate-driven locations

Energy & PUE Reductions

Reducing PUE doesn't necessarily mean reduction in energy utilization

First 3 bars all have same PUE, but different monthly KWH

Applying PUE reductions reduce energy utilization



C.S. Base = Case Study Baseline system

C.S. Virt = Case Study system, virtualized, after 24 months of upgrades

- Green Capacity Planning
 - Energy is a resource
 - Introduce Energy Footprint Projection
 - Expands traditional capacity planning
- Case Study
 - Demonstrates the methodology
 - Analyzes alternative infrastructures
 - Reduces energy footprint with Virtualization
- Value
 - Actionable metrics
 - Quantifies IT and Site energy usage & costs
 - Supports responsible decision making
 - Bridges the gap between IT & Facilities

Primary Reference

This presentation is based upon a 2008 study by:

Amy Spellmann, Optimal Innovations

amy@optimalinnovations.com

Richard Gimarc, Hyperformix

rgimarc@hyperformix.com

Charles Gimarc, LSI Corporation

Charles.Gimarc@lsi.com

And a paper presented at the 2008 Computer Measurement Group conference, December 2008. The paper may be downloaded from:

http://www.optimalinnovations.com/pdf/green_capacity_planning.pdf

- [ACC2008] "Data Center Energy Forecast Report, Final Report, July 2008
- [EPA2007] "Report to Congress on Server and Data Center Energy Efficiency", U.S. Environmental Protection Agency, August 2008
- [KOOM2007] "Estimating Regional Power Consumption By Servers", Jonathan G. Koomey, LBNL Tech Note
- [SPEC2008] SPECpower_ssj2008, Feb 27, 2008, Dell PowerEdge 2950 III (Intel Xeon E5440)
- [TGG2007] "The Green Grid Data Center Power Efficiency Metrics: PUE and DCiE", 2007, The Green Grid, Page 6
- [TGG2008] "Five Ways to Reduce Data Center Server Power Consumption", 2008, Mark Blackburn, The Green Grid, Page 5
- [GCP2008] "Green Capacity Planning: Theory and Practice", Spellmann Gimarc & Gimarc, CMG 2008
- [GCP-b2008] "Green Capacity Planning", 2008, C. Gimarc, http://wikibon.org/?c=wiki&m=v&title=Green_Capacity_Planning